



City of Grand Prairie Fire Department Code Regulations

Building Signage

In addition to the building address, areas housing fire protection systems and other equipment critical to the building's function must be clearly identified.

Building Area/ Equipment Contained	Color Scheme	Letter Height (inches)	Letter Stroke Width (inches)	Sign Location	Sign Wording
Fire sprinkler riser room	Red letters on a white sign	4	NOT SPECIFIED	Exterior door	FIRE SPRINKLER RISER ROOM
Fire sprinkler riser room	Red letters on white sign	2	NOT SPECIFIED	Interior door	FIRE SPRINKLER RISER ROOM
Fire pump	Red letters on white sign	4	NOT SPECIFIED	Exterior door	FIRE PUMP ROOM
Fire alarm panel	Red letters on white sign	2	NOT SPECIFIED	Interior door	FIRE ALARM PANEL
Electrical room	NOT SPECIFIED	Visible and legible	Per NEC	On exterior of door	ELECTRICAL ROOM
Blocked door from inside	Contrasting to background	6	$\frac{3}{4}$	On exterior of door	THIS DOOR BLOCKED

All electrical equipment shall be labeled in accordance with the requirements of the *National Electrical Code (NEC)*®.