

**ANYONE'S ELECTRIC COMPANY  
GRAND PRAIRIE, TEXAS 75050**

**To Whom It May Concern:**

**As required by the City of Grand Prairie Article XVII. Swimming Pools and Spas 13-442 (b) an annual Ground Fault Circuit Interrupter inspection for wet niche fixtures was performed at the following establishment(s):**

---

---

**The inspection process was as follows:**

1. Visual inspection of GFCI
2. Activation of the internal test circuit equipment built into the breaker by the manufacturer
3. Simulated fault in the circuit conductor to activate the GFCI
4. Ground continuity testing

**The tests were performed by *Electrician's Name***

**TECL # XXXXXXXXXX**

**Date: 01/01/1900**

Signature \_\_\_\_\_